



Product Service

# Attestation of Conformity

No. E8A 111906 0001 Rev. 00

**Holder of Certificate:** **Gas DNA Co., Ltd.**  
101, Bukhang-ro 193beon-gil, Seo-gu  
Incheon 22856  
REPUBLIC OF KOREA

**Name of Object:** **Sensors**  
**(Smoke Detector)**

**Model(s):** **ASD-55, ASD-56, ASD-57**

**Description of Object:** Rated input voltage: 22-26 V d.c.  
Rated input current: 60 mA

**Tested according to:** EN 50270:2015  
EN 61000-6-4:2007/A1:2011  
EN IEC 61000-6-4:2019  
EN 61000-6-2:2005  
EN IEC 61000-6-2:2019

This Attestation of Conformity is issued on a voluntary basis according to the Directive 2014/30/EU relating to electromagnetic compatibility. It confirms that the listed apparatus complies with all essential requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** CTK-2021-00797

**Date,** 2021-03-15

( Byung-Soo Kang )

Page 1 of 1

After preparation of the necessary technical documentation as well as the EU Declaration of conformity the required CE marking can be affixed on the product. That Declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.